



BID BULLETIN 01

Date: 26 November 2021
Project Title: Supply and Delivery of Electrical Equipment and Supplies (GOODS-21-59)
Location: VSU Main, Visca, Baybay City, Leyte

Bidders are hereby informed/reminded of the following addendums/amendments/clarifications:

I. LIST OF REQUIREMENTS

(1st Envelope) TECHNICAL COMPONENT ENVELOPE	
<i>Legal Documents</i>	
1	PhilGEPS Certificate of Registration (Platinum) or a. Registration Certificate (SEC, DTI or CDA) b. Mayor's/Business Permit c. Tax Clearance
<i>Technical Documents</i>	
2	Statement of All On-Going Government & Private Contracts
3	Statement of Bidder's Single Largest Completed Contract (at least 50% of the ABC or Php 1,165,425.00) Or Statement of at least two (2) similar completed contracts w/ total amount of at least Php 1,165,425.00 and the largest of which should be at least Php 582,712.50 .
4	Bid Security
5	Technical Specifications
6	SCHEDULE of Requirements/Production and delivery schedule
7	Manpower Requirements
8	After Sales service/parts from acceptance of delivered goods (at least 1 year for equipment and 3 months for supplies)
9	Original Duly Signed Omnibus Sworn Statement
<i>Financial Documents</i>	
10	The Supplier's Audited Financial Statements
11	Net Financial Contracting Capacity (at least Php 2,330,850.00) Or Committed Line of Credit (at least Php 233,085.00)
(2nd Envelope) FINANCIAL COMPONENT ENVELOPE	
12	Original of duly signed and accomplished Financial Bid Form
13	Original of duly signed and accomplished Price Schedule(s)



Please take note:

In the **Technical Specifications**, bidders must state either “Comply” or “Not Comply” **against each of the individual parameters of the specifications** per item stating the corresponding performance parameter of the equipment offered. Statements of “Comply” or “Not Comply” must be supported by evidence in the **Bidders Bid** and cross-referenced to that evidence. Evidence shall be in the form of **manufacturer’s un-amended sales literature (Data Sheets), unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data, and Brand and Model** as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of **ITB** Clause 3.1(a)(ii) and/or **GCC** Clause 2.1 (a)(ii).

II. Preparation of Electronic Bid (for bidders who prefer electronic bid submission)

1. Convert all documents into Portable Document Format (PDF) and should be printable.
2. Properly label all documents for prompt identification. Filename of documents, whichever are applicable to the bidder, should be as follows:

Document	Filename (in PDF form)
1. PhilGEPS Certificate of Registration (Platinum)	PhilGEPS
2. Registration Certificate (SEC/DTI)	Registration Certificate
3. Mayor’s/Business Permit	Mayor’s-Business Permit
4. Tax Clearance	Tax Clearance
5. Statement of On-Going Government & Private Contracts	Statement of On-Going Contracts
6. Statement of Bidder's Single Largest Completed Contract	SLCC
7. Statement of at least two (2) similar completed contracts	Statement of Completed Contracts
8. Bid Security	Bid Security
9. Technical Specifications	Technical Specifications
10. SCHEDULE of Requirements/Production and delivery schedule	Schedule of Requirements
11. Manpower Requirements	Manpower Requirements
12. After Sales service/parts	After Sales
13. Omnibus Sworn Statement	Omnibus Sworn Statement
14. Audited Financial Statements	Audited Financial Statements
15. Net Financial Contracting Capacity	NFCC
16. Committed Line of Credit	CLC
17. Bid Form	Bid Form
18. Price Schedule	Price Schedule

3. Create two (2) folders that are password-protected. The first folder should contain all requirements under Technical Component checklist as presented under Section VIII.



The second folder should contain all requirements under Financial Component checklist.

4. Compress the two (2) folders and name as follows: a) first folder: **Technical Documents**, b) second folder: **Financial Documents**.
5. Email the 2 compressed folders to Ms. Jessamine C. Ecleo at jessamine.ecleo@vsu.edu.ph before the deadline.

III. Changes in the Bidding Documents

Original	Amendment
<p>5. A complete set of Bidding Documents may be acquired by interested Bidders on <i>15 November – 06 December 2021 until 1:30 PM</i> from the given address and website(s) below and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of Five Thousand Pesos (PhP 5,000.00). The Procuring Entity shall allow the bidder to present its proof of payment for the fees in person, by facsimile, or through electronic means.</p>	<p>5. A complete set of Bidding Documents may be acquired by interested Bidders on <i>15 November – 06 December 2021 until 1:30 PM</i> from the given address and website(s) below and upon payment of the applicable fee for the Bidding Documents, pursuant to the latest Guidelines issued by the GPPB, in the amount of Five Thousand Pesos (PhP 5,000.00). The Procuring Entity shall allow the bidder to present its proof of payment for the fees in person, by facsimile, or through electronic means.</p> <p>The Bidders may also deposit the applicable fee to Visayas State University Landbank Account:</p> <p>Account Name: Visayas State University Fund 164 Account Number: 3572-1000-13</p> <p>And send the deposit slip to Ms. Jessamine C. Ecleo at jessamine.ecleo@vsu.edu.ph</p>



IV. Revised List of Goods and Technical Specifications

- Some Specifications were added (red) and/or deleted (blue)
- Some Quantities and Unit Prices (ABC) were changed

Item No.	Description	ABC/Unit	Total ABC
1	(1 LOT) Electrical Equipment and Supplies for Various Electrical Repair and Maintenance	2,330,850.00	2,330,850.00
	(1) Transformer, Distribution, 75 KVA (2 units)		
	Specification:		
	* 75 KVA OISC		
	* Copper to copper winding both primary and secondary		
	* 8 KV with changer 2-2 1/2% above rated primary voltage & 2-2 1/2% below rated primary voltage double bushing Secondary voltage 120/240 volts with changer tap		
	* Pad/pole mounted Amorphous Metal Core		
	(2) 15 Amperes, Type K Fuselinks (2 boxes)		
	Specification:		
	* 15 Amperes, Type K Fuselinks, 23" length, removable head, stainless steel strain wire and a silver copper fuse wire fuse element (ANSI/IEEE/NEMA certified)		
	(3) 25 Amperes, Type K Fuselinks (2 boxes)		
	Specification:		
	* 25 Amperes, Type K Fuselinks, 23" length, removable head, stainless steel strain wire and a silver copper fuse wire fuse element (ANSI/IEEE/NEMA certified)		
	(4) Angle Bar, 1/4"(thickness) x 1-1/2" x 1-1/2" X 20 ', Standard (5 lengths)		
	(5) ANSI Thimble Eye Anchor Rod 5/8" x 10" (5 sets)		
	(6) ANSI Thimble Eye Anchor Rod 5/8" x 48" (5 sets)		
	(7) BOLT and NUt with Washer 1", 1 inch (40 pcs)		
	(8) Clevis Insulator with Polymer Spool (30 pcs)		
	(9) Cut-Out Set, Porcelain, 15 KV outdoor type with mounting bracket, with fuse holder, 15 K lighting arrest (4 sets)		
	(10) 15 kV, 110 kV BIL, Type C standard polymer cutout w/100A, 10kAIC fuseholder with 15k lighting arrest (3 units)		
	(11) Electrical LED floodlights, 50 watts waterproof lamp outdoor spotlight (20 pcs)		
	(12) Electrical (PVC) Long Sweep Elbow, 3/4" x 90deg (50 pcs)		
	(13) Electrical (PVC), Long Sweep Elbow, 1/2" x 90deg (50 pcs)		



(14) Electrical (PVC), Long Sweep Elbow, 2" x 90deg (25 pcs)		
(15) Electrical Entrance Cap, 1" diameter (3 pcs)		
(16) Electrical LED flood Lights, (Metal Halide), 400 watts (6 pcs)		
(17) Electrical Panel Board, 6-Branch (1 set)		
Specification:		
Panel Board 6 Branches:		
* Dead front		
* Copper bus bar		
* single phase metal enclosure of		
* 1 pc. Circuit breaker, center main 70 amps 2 pole, molded bolt on type		
* 4 pcs Circuit breaker 20 amps 2 pole, molded, bolt on type		
* 2 pcs Circuit Breaker 15 amps 2 pole, molded bolt on type		
(18) Electrical Pole, (Galvanized Steel), Hexagonal, 30 feet (11 pcs)		
(19) Electrical Pole, Galvanized Steel, (Hexagonal), 35' (5 pcs)		
(20) Electrical Pull Box, (Metal) 4" x 6" (3 pcs)		
(21) Electrical Rubber Tape # 15, Self-infusing (15 rolls)		
(22) Electrical Tape (Rubber) (50 pcs)		
0.8 x 19mm x 8m any color		
(23) Electrical Wire , TF AWG 16 (1.25 mm ²), Stranded, 150m/box (30 boxes)		
Heat resistant		
Waterproof		
(24) Electrical Wire, Bare ACSR, (Stranded) # 4 for neutral line (1,000 meters)		
(25) Electrical Wire, Insulated ACSR, (Stranded) # 4 (300 meters)		
(26) Electrical Wire, Stranded Insulated ACSR for 22.9 KV, 32 mm (1,000 meters)		
(27) Electrical Wire, THHN / THWN, AWG 10 (5.5mm ²), Stranded, 150 meters/box (8 boxes)		
Specification:		
* Building Wire		
* Stranded with Nylon Insulation		
* Gauge 10		
* UL listed		
(28) Electrical Wire, THHN / THWN, AWG 12 (3.5mm ²), Stranded, 150 meters/box (6 boxes)		
Specification:		



* Building Wire		
* Stranded with Nylon Insulation		
* Gauge 12		
* UL listed		
(29) Electrical Wire, THHN/THW Wire 2/0 AWG (50 mm2) (450 meters)		
(30) Electrical Wire, THHN/THWN AWG 2/0(60 mm²), Stranded wire (300 meters)		
(31) Electrical Wire, THHN/THWN AWG 8(8.0 mm2), Stranded copper wire 600 volts, at least 150 meters per box (3 boxes)		
(32) Electrical Wire, THHN/THWN, AWG 2 (30 mm2), Stranded (150 meters)		
Specification:		
* Building Wire		
* Stranded with Nylon Insulation		
* Gauge 2		
* UL listed		
(33) Electrical Wire, THHN/THWN, AWG 6(14 mm2), Stranded Wire 600 volts at least 150 meters per roll(2 rolls)		
(34) Electrical Wire, THHN/THWN, AWG 8 (8mm2), Stranded, 150 meters/box (5 boxes)		
Specification:		
* Building Wire		
* Stranded with Nylon Insulation		
* Gauge 8		
* UL listed		
(35) Electrical, (PVC) Male Adaptor, 1" diameter (3 pcs)		
(36) Electrical, Ground Rod, Trimble-eye bolt (10 pcs)		
(37) Electrical, Photocell Control Switch, Electric 10A, 230V (5 pcs)		
Specification:		
* Streetlight, Auto on/off sensor switch		
* Durable, Heavy Duty, Good Quality		
(38) Electrical, Pipe, (PVC) Orange, 1"(32mm) x 3m (10 lengths)		
Specification:		
* Sched 40, Durable, Good Quality		
(39) Electrical, Pipe, (PVC) Orange, 3/4"(25mm) x 3m (200 lengths)		
Specification:		
* Sched 40, Durable, Good Quality		
(40) Electrical, PVC Pipe (Orange), 1/2" x 10 feet (100 lengths)		
(41) Electrical, PVC Pipe (Orange), 2" x 10 feet (50 lengths)		



	(42) Eye Bolt, 5/8" x 10" (20 pcs)	
	(43) Galvanized Guy Clamp, 3" bolt (15 pcs)	
	(44) Machine Bolt 3/8" x 6" with locknut and washer (5 sets)	
	(45) Machine Bolt 3/8" x 8" with locknut and washer (5 sets)	
	(46) Machine bolt, 5/8" x 10" with locknut & washer (50pcs)	
	(47) Machine Bolt, 5/8" x 14" with locknut & washer (30pcs)	
	(48) Molded Case Breaker, (Bolt on type) 15 amps 2 pole (3 pcs)	
	(49) Molded Case Breaker, (Bolt on type), 100 amps 2 pole Center main MCCB (1 pc)	
	(50) Molded Case breaker, (Bolt on type), 20 amps 2 pole (3 pcs)	
	(51) Molded Case Breaker, (Bolt on type), 30 amps 2 pole (4 pcs)	
	(52) Molded Case Breaker, (Bolt on type), 40 amps 2 pole (4 pcs)	
	(53) Panel Board, Dead Front, Single Phase, Copper Bush Bar Metal Enclosed (2 sets)	
	Specification:	
	* To consist of the ff. with grounding terminal	
	a) 1 pc Molded Circuit Breaker, center main 70 amps 2 poles, 240 volts, bolt on type	
	b) 1 pc Molded Circuit Breaker, Branch 15 amps 2 poles, bolt on	
	c) 2 pcs Molded Circuit Breaker, Branch 20 amps 2 poles, bolt on	
	d) 2 pcs Molded Circuit Breaker, Branch 30 amps 2 poles, bolt on	
	e) 1 pc Molded Circuit Breaker, Branch 40 amps 2 poles, bolt on	
	(54) Pipe (G.I.), 2" diameter, Sched 40, 20 feet (10 lengths)	
	(55) Pipe (G.I), 4" diameter, Sched 40, 20 feet (2 lengths)	
	(56) Quadrant Dead End Clamp (20 pcs)	
	(57) Receptacle Socket, 4" x 4" (20 pcs)	
	(58) Secondary Rack, (Single phase) (3 pcs)	
	(59) Shackle Insulator, 250mm x 250mm (20 pcs)	
	(60) Solderless Connector 1/0 AWG Split Type (10 sets)	
	(61) Solderless Connector 2/0 AWG Split Type (10 sets)	
	(62) Solderless Connector, (Split type), 30mm (6 rolls)	
	(63) Steel Pin Pole with Polymer insulator, 15 KV (20 pcs)	



(64) Suspension Polymer (20 pcs)		
(65) Swing clevis with insulator (5 sets)		
(66) Truss Guy (4 sets)		
(67) Bulb, LED, 9W (100 pcs)		
(68) Cement, Portland (20 bags)		
Specification:		
* Type 1P, Premium Quality		
* ASTM C150		
(69) Insulation Adhesive Electrical Tape, 30mm (70 rolls)		
(70) Steel Bar, Deformed(Corrugated),10mm x 6m (5 lengths)		
Specification:		
* 0.616 kg/M PNS 230		
* ASTM / Grade 33 Structural		
(71) Welding Rod, E-6011, 1/8" (10 kilos)		
* Premium Quality		
TOTAL:		2,330,850.00

Sgd.
DILBERTO O. FERRAREN
BAC Chairman